



## Fire Marshal's Office

1500 Highway 66  
Garland, TX 75040  
(972) 781-7148  
(972) 781-7142 – fax

### FIRE HYDRANTS

Revised 11/02/18

- Fire hydrants must be installed, charged and accepted during construction **before** any walls or vertical construction elements are raised.
- A fire hydrant is required within 400 feet of all portions of any building constructed or moved into or within the City of Garland as measured by an approved route around the exterior of the facility or building.
- A fire hydrant is required within 600 feet of all portions of Group R-3, Group U occupancies and all buildings equipped throughout with an approved automatic sprinkler system.
- Fire hydrants must be no further than eight feet and no closer than three feet from the fire lane or public way.
- A fire hydrant threatened by vehicular traffic may require vehicle impact protection upon inspection by an FMO representative.

For items not listed refer to 2015 IFC, local amendments, and any material deemed applicable by the Fire Marshal. <http://www.garlandtx.gov/312/Fire-Prevention>

**This list is provided as an aid for submittals only, and is not intended to cover every code requirement.**